



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF PRECAST COVER SLAB

Lab ID : CP-2017-04-25-01 Date: 29-04-2017

Customer : Assistant Executive Engineer, Byatarayanapura Sub Division, BBMP, Bangalore.

Address : Byatarayanapura Sub Division, BBMP, Bangalore.

Project Name : Improvemets of Drains and construction of culverts in Dasarahalli Sorrounding area in ward No.6 Byatarayanapura Sub Division.

Agency : Sri.K. Shankar Reddy, No.46/2, Kaverinagara, Kavalbyrasandra, Bangalore-560002.

Customer's Reference : BBMP/EE/BTP/WO/32/2016-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 25-04-2017

Sample ID No : 2017-04-25-01/01

Sample Type /Size : Precast Cover Slab

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete

Date of test : 26/04/2017

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	(mm)	(Sq.mm)	(KN)	(N/mm ²)	(N/mm ²)	(N/mm ²)
1	Cover Slab-1	75.48	100.48	1.116	4474	95.3	21.3	19.8	24.8
2	Cover Slab-2	75.54	100.52	1.122	4481	94.3	21.0	19.6	24.5
3	Cover Slab-3	75.53	100.51	1.118	4480	97.2	21.7	20.2	25.2

Note:

The results pertain to the samples received and tested.
 All information furnished by the Customer/Representative
 Any correction in the report will make this report invalid
 This report without prior written approval should not be reproduced or published in full or part.
 Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

Handwritten signature and stamp of Harshitha



FOR CIVIL Pro.

Handwritten signature of Karthik Rechan
 KARTHIK RECHAN
 Authorized Signatory
 Quality Manager

Page 1/1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
 GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

TEST REPORT OF PRECAST COVER SLAB

Lab ID : CP-2017-05-03-01 Date: 08-05-17

Customer : Assistant Executive Engineer, Byatarayanapura Sub Division, BBMP, Bangalore.

Address : Byatarayanapura Sub Division, BBMP, Bangalore.

Project Name : Improvemets of Drains and construction of culverts in Dasarahalli Sorrounding area in ward No.6 Byatarayanapura Sub Division.

Agency : Sri.K. Shankar Reddy, No.46/2, Kaverinagara, Kavalbyrasandra, Bangalore-560002.

Customer's Reference : BBMP/EE/BTP/WO/32/2016-17

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 26-04-17

Sample ID No : 2017-05-03-01/01

Sample Type /Size : Precast Cover Slab

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete

Date of test : 26/04/2017

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	(mm)	(Sq.mm)	(KN)	(N/mm ²)	(N/mm ²)	(N/mm ²)
1	Cover Slab-1	74.92	100.51	1.298	4408	97.8	22.2	20.6	25.8
2	Cover Slab-2	75.02	100.52	1.258	4419	96.8	21.9	20.4	25.5
3	Cover Slab-3	75.09	100.50	1.267	4428	101.5	22.9	21.3	26.6

Note:

The results pertain to the samples received and tested.
All information furnished by the Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 30 days from the date of issue of test certificate

Prepared by
Harshitha

(Signature)
ಪ್ರಾಧಿಕಾರಿತರಾಗಿ
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಜ್ಯೋತಿಯನಪರ ಉಪ ನಿರ್ದೇಶಕರು



FOR CIVIL Pro.

(Signature)
R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |